



Cable ID: NEXT


Date / Time: 2017/12/01 04:10:24 PM
Headroom 3.9 dB (NEXT 12-36)
Test Limit: 10GBASE-T
Cable Type: Cat 6A U/UTP
NVP: 68.2%

Operator: RITESH PATEL
Software Version: 2.7700
Limits Version: 1.9400
Calibration Date:
Main (Tester): 2015/12/25
Remote (Tester): 2015/12/25


Test Summary: PASS

Model: DTX-1800
Main S/N: 9692119
Remote S/N: 9692120
Main Adapter: DTX-CHA002
Remote Adapter: DTX-CHA002

Length (m)		N/A
Prop. Delay (ns)	[Pair 45]	514
Delay Skew (ns)	[Pair 45]	23
Resistance (ohms)		N/A



Wire Map (T568B)
PASS



	Worst Case Margin		Worst Case Value	
PASS	MAIN	SR	MAIN	SR
Worst Pair	12-36	12-36	12-78	36-45
NEXT (dB)	3.9	5.1	13.7	10.0
Freq. (MHz)	14.0	78.5	451.0	465.0
Limit (dB)	54.2	41.7	24.2	23.6

Compliant Network Standards:

10BASE-T	100BASE-TX	100BASE-T4
1000BASE-T	10GBASE-T	ATM-25
ATM-51	ATM-155	100VG-AnyLan
TR-4	TR-16 Active	TR-16 Passive

